



- TAS GENERAL NOTES:**
- INFORMATION SHOWN ON THIS SHEET IS THE MINIMUM REQUIRED BY TEXAS ACCESSIBILITY STANDARDS; (TAS) TEXAS DEPARTMENT OF LICENSING AND REGULATION (TDLR)
  - REF. HANDICAP MOUNTING HEIGHTS LOCATED ON G1.1 FOR ACCESSIBLE AND STANDARD MOUNTING HEIGHTS OF ALL FIXTURES & ACCESSORIES LOCATED THROUGHOUT CONTRACT DOCUMENTS.
  - NOT ALL CONDITIONS SHOWN ON THIS SHEET MAY BE REQUIRED BY THIS PROJECT. COMPARE THE REQUIREMENTS OF THE ARCHITECTURAL DRAWINGS WITH THIS SHEET FOR RELEVANCE OF INFORMATION.
  - DIMENSIONS INDICATED ARE THE MINIMUM CLEAR DIMENSIONS REQUIRED BY THE TEXAS ACCESSIBILITY STANDARDS (T.A.S.) THE CONTRACTOR IS RESPONSIBLE FOR LAYOUT OF BUILDING ELEMENTS TO ASSURE THAT DIMENSIONS SHOWN ARE PROVIDED.
  - DIMENSIONS SHOWN ON INTERIOR ELEVATIONS AT WALLS ARE TO THE FINISHED SURFACE.
  - DIMENSIONS TO BOTTOM OF MIRRORS ARE TO THE REFLECTIVE SURFACE, NOT TO THE FRAME.
  - NOTIFY THE ARCHITECT IMMEDIATELY OF ANY DISCREPANCIES BETWEEN THE ARCHITECTURAL DRAWINGS AND THE INFORMATION GIVEN ON THIS SHEET - PRIOR TO INSTALLATION
  - ALL EXPOSED PIPE AND VALVES UNDER SINKS ARE TO BE INSULATED.
  - DO NOT SCALE THESE DRAWINGS.
  - PROVIDE WOOD BLOCKING AS NEEDED TO SECURE GRAB BARS AND SHOWER SEATS TO STUD FRAMING WALLS.
  - HANDICAP ACCESSIBLE SHOWERS ARE TO BE RECESSED INTO CONCRETE TOPPING & TOPPING WARDING AS REQUIRED TO HAVE NO MORE THAN A 1/2" LIP AT EDGE OF SHOWER ENTRY.
  - PLEASE ENSURE CURB RAMPS ARE CONSTRUCTED WITHIN TAS SPECIFICATIONS PER SECTION 207.1