



Casey Slone Construction, L.L.C.

Gregg County Youth Center Building Renovations RFP

RFI Response 02/06/19

RFI regarding Safety Cell Padding

Doug - after a lot of studying,,, do you realize that to get the warranty you must;

1. the manufacturer MUST install the product.
2. Sign off on THEIR stationary that there is an effective vapor barrier present. *there's a lot of other wording but,,
3. Sign off that there is no presence of contaminants in the concrete substrate.

*there is a lot of notes that a "prime coat" will not count towards a warranty.

***My request here is, supply an answer about all 3 above as I (as the customer) can not give that "sign off" needed for warranty purposes.

therefore, will the warranty be waived? this needs to be cleared up regardless. Assuming other contractors are reading the fine details and talking to the supplier.

**The primecoat representative stated the following in a phone call on 02/13/19:
Yes the manufacturer must install the product and will install an effective vapor barrier if required. The contaminants in the concrete is referring to oils or acids that cannot be cleaned from the concrete. This is not referencing the concrete mix composition and is not an issue for this project.**