

Vendor Questions and Answers (3)
Bid 2017-705, Training Facility Precinct 3
Gregg County, Texas

1. The spec calls for a weather tight warranty, this is not available with a screw down roof which is specified. Please advise that this will be waived or will the roof panel be changed to a stand and seam roof panel? **The screw down roof shall remain as specified the weather tight warranty shall be waived. The standard manufacturer's warranty shall apply as well as a 5 year warranty from the Installer and the General Contractor for workmanship and weather tightness. This is in addition to the standard one year warranty on the entire project.**

2. Regarding the tie-in to the downspouts to the storm drain piping, can you clarify the exact type or style connection that is desired please. **See Attached Detail.**

3. Manufacturer shall be Alliance Building System or approved substitute. **The Metal Building Manufacturer must be a member of the MBMA. If they are not a member, they are not approved.**

4. Section 13122 Metal Building Systems design does not match Sheet S1.0. Nor does it match Sheet G2.0. Which design sheet is to be used? **See RFI#2 for complete answer.**