

Vendor Questions and Answers (2)
Commercial HVAC Preventative Maintenance
Services and Repairs for Gregg County, Texas
RFP# 2023-15

1. Are the contractors supposed to supply and replace all filters?

Answer: Only change on the AHU units.