

**Vendor Questions and Answers (3)  
Generator Maintenance and Services  
Gregg County, Texas  
RFP 2021-07**

**PLEASE CANCEL THE REQUIREMENTS FOR SWITCHGEAR  
PREVENTATIVE MAINTENANCE AS ANSWERED IN VENDOR Q&A 2**

1. Can you provide a copy of the standard 100+ point inspections and equipment test requirements?

**See attached to this document.**

**Included is insulation testing (performed annually)**

**Fuel analysis (performed annually)**

**~~Switchgear preventative maintenance (performed annually)~~**